


LAMP PHOTOMETRIC REPORT

MODEL: 95Livial60/BL		
POWER: 10W	VOLTAGE: 230V	WORKING VOLTAGE: 230V
MANUFACTURER: Elmark Industries JSC		

TOTAL FLUX: 799.15 lm



$\gamma$	C0	C45	C90	C135	C180	C225	C270	C315	$\gamma$	$\Phi$ zone	$\Phi$ total	%
10	386.8	385.2	384.3	384.1	386.2	387.9	387.9	388.4	0- 10	37.30	37.30	4.67
20	361.5	358.5	356.1	354.8	359.8	364.2	363.9	365.7	10- 20	105.9	143.2	17.9
30	317.1	311.3	308.6	308.0	317.6	321.8	321.7	323.2	20- 30	156.7	299.9	37.5
40	250.4	244.5	242.2	242.2	252.4	258.6	260.3	260.0	30- 40	178.5	478.4	59.9
50	163.1	159.1	158.7	157.5	165.5	174.0	177.1	172.9	40- 50	161.9	640.3	80.1
60	69.05	70.22	71.53	70.48	79.38	83.18	82.50	80.19	50- 60	106.1	746.4	93.4
70	17.98	17.99	19.26	18.20	21.04	23.34	23.68	21.67	60- 70	44.30	790.7	98.9
80	0.5520	0.5328	0.4907	0.3289	0.4623	0.7872	0.9012	0.9940	70- 80	8.145	798.9	100
90	0.1710	0.1787	0.1773	0.1675	0.1202	0.1246	0.1255	0.1318	80- 90	0.2793	799.1	100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG  
C Interval: 10.0DEG  
Test Speed: MEDIUM  
Temperature:25.3°C  
Operators:  
Test Date:19 December 2022

$\gamma$  Range: 0 - 90DEG  
 $\gamma$  Interval: 2.5DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.00.456  
Humidity:65.0%  
Test Distance:6.265m [K=1.0000]  
Remarks:

```

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

```

```

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

```