

Floodlight Summary:

Report based on lamp delivering 1000 lumens.

Maximum Intensity	5023.9 cd per klm.
(Luminaire orientation as tested.)	0.0 degrees vertical
	0.0 degrees horizontal

Beam Spread	At 10% of Imax	42.8V x 42.9H
	At 50% of Imax	17.4V x 17.6H
	At 90% of Imax	5.9V x 6.7H

Beam Flux	Total	946.5 lumens per klm.
	To 10% of Imax	625.9 lumens per klm.
	To 50% of Imax	269.0 lumens per klm.
	To 90% of Imax	47.1 lumens per klm.

Upward LOR	0.0 %
Downward LOR	94.7 %


Luminaire Efficiency (Light Output Ratio)	94.2 %
---	--------

C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: MEDIUM
Temperature: 25.3°C
Operators:
Test Date: 24 January 2023

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity: 65.0%
Test Distance: 6.340m [K=1.0000]
Remarks:

LUMINAIRE PHOTOMETRIC TEST REPORT

NAME: 96GRF1/515220W	TYPE:	WEIGHT: 1
SPEC.:	DIM.: F 115 x 90	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: 5 Circle	Shielding Angle:



DATA OF LAMP		PHOTOMETRIC DATA	
MODEL	96GRF1/515220W	Imax (cd)	2010
NOMINAL POWER (W)	5	AVAILABILITY (%)	61.6
RATED VOLTAGE (V)	230	Avai. FLUX (lm)	246.3
NOMINAL FLUX (lm)	400	LOR (%)	94.2
LAMPS INSIDE	1	TOTAL FLUX (lm)	376.7
TEST VOLTAGE (V)	230	θ @50% (H,V)	18,17DEG

VERTICAL (DEG)	AREA FLUX DIAGRAM																UNIT: lm		Φ t	Φ a
	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.00
90	0.00	0.00	0.00	0.01	0.02	0.03	0.04	0.04	0.05	0.05	0.04	0.03	0.02	0.01	0.01	0.00	0.00	0.00	0.35	0.00
80	0.00	0.00	0.01	0.03	0.05	0.08	0.10	0.13	0.14	0.14	0.13	0.10	0.07	0.04	0.02	0.01	0.00	0.00	1.03	0.00
70	0.00	0.00	0.02	0.05	0.10	0.16	0.23	0.30	0.34	0.34	0.29	0.22	0.14	0.08	0.04	0.01	0.00	0.00	2.34	0.00
60	0.00	0.01	0.03	0.08	0.17	0.31	0.51	0.70	0.77	0.75	0.64	0.48	0.30	0.15	0.07	0.03	0.00	0.00	5.01	0.00
50	0.00	0.01	0.04	0.12	0.27	0.54	0.95	1.43	1.79	1.77	1.39	0.89	0.53	0.26	0.10	0.04	0.01	0.00	10.1	0.00
40	0.00	0.01	0.05	0.16	0.39	0.84	1.78	3.18	4.44	4.38	3.05	1.68	0.79	0.37	0.14	0.05	0.01	0.00	21.3	1.15
30	0.00	0.01	0.06	0.19	0.50	1.25	3.04	6.39	11.3	11.0	6.05	2.86	1.14	0.46	0.18	0.05	0.01	0.00	44.5	29.9
20	0.00	0.01	0.07	0.21	0.59	1.57	4.15	11.1	37.8	35.8	10.2	3.90	1.42	0.52	0.19	0.06	0.01	0.00	108	95.7
10	0.00	0.01	0.06	0.21	0.60	1.57	4.10	10.8	35.9	33.9	10.1	3.88	1.42	0.53	0.19	0.06	0.01	0.00	103	91.3
0	0.00	0.01	0.06	0.19	0.53	1.24	2.99	6.21	10.4	10.2	6.00	2.86	1.13	0.47	0.17	0.05	0.01	0.00	42.5	27.5
-10	0.00	0.01	0.05	0.15	0.40	0.83	1.71	3.12	4.32	4.22	2.98	1.64	0.77	0.37	0.14	0.04	0.01	0.00	20.8	0.70
-20	0.00	0.01	0.04	0.11	0.26	0.52	0.88	1.39	1.76	1.70	1.29	0.82	0.49	0.25	0.10	0.03	0.01	0.00	9.66	0.00
-30	0.00	0.01	0.03	0.08	0.15	0.29	0.46	0.64	0.76	0.74	0.61	0.45	0.28	0.14	0.06	0.02	0.00	0.00	4.73	0.00
-40	0.00	0.00	0.02	0.05	0.10	0.15	0.22	0.29	0.33	0.33	0.28	0.21	0.14	0.08	0.04	0.01	0.00	0.00	2.26	0.00
-50	0.00	0.00	0.01	0.02	0.05	0.08	0.10	0.12	0.12	0.12	0.11	0.09	0.07	0.04	0.02	0.01	0.00	0.00	0.97	0.00
-60	0.00	0.00	0.00	0.01	0.01	0.02	0.03	0.04	0.04	0.04	0.04	0.03	0.02	0.01	0.01	0.00	0.00	0.00	0.31	0.00
-70	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.04	0.00
-80	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	-90	-80	-70	-60	-50	-40	-30	-20	HORIZONTAL (DEG)	20	30	40	50	60	70	80	90			
Φ t	0.01	0.12	0.56	1.67	4.19	9.49	21.3	45.8	110	105	43.2	20.2	8.74	3.79	1.48	0.48	0.10	0.01	377	---
Φ a	0.00	0.00	0.00	0.00	0.00	0.00	1.26	29.8	96.3	91.4	26.9	0.60	0.00	0.00	0.00	0.00	0.00	0.00	---	246

one-half-peak spread: U:8.5,D:9.1 , L:9.2,R:8.5


NEMA Beam Type: Type 3

C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: MEDIUM
Temperature:25.3°C
Operators:
Test Date:24 January 2023

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.340m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

NAME: 96GRF1/515220W	TYPE:	WEIGHT: 1
SPEC.:	DIM.: F 115 x 90	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: 5 Circle	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: MEDIUM
Temperature: 25.3°C
Operators:
Test Date: 24 January 2023

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity: 65.0%
Test Distance: 6.340m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


NAME: 96GRF1/515220W	TYPE:	WEIGHT: 1
SPEC.:	DIM.: F 115 x 90	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: 5 Circle	Shielding Angle:



C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: MEDIUM
Temperature: 25.3°C
Operators:
Test Date: 24 January 2023

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity: 65.0%
Test Distance: 6.340m [K=1.0000]
Remarks:

Planar Illuminance Curve




C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: MEDIUM
Temperature: 25.3°C
Operators:
Test Date: 24 January 2023

γ Range: 0 - 90DEG
 γ Interval: 2.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity: 65.0%
Test Distance: 6.340m [K=1.0000]
Remarks:

AAI Figure

NAME: 96GRF1/515220W	TYPE:	WEIGHT: 1
SPEC.:	DIM.: F 115 x 90	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: 5 Circle	Shielding Angle:



Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
 C Interval: 10.0DEG
 Test Speed: MEDIUM
 Temperature:25.3°C
 Operators:
 Test Date:24 January 2023

γ Range: 0 - 90DEG
 γ Interval: 2.5DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
 Humidity:65.0%
 Test Distance:6.340m [K=1.0000]
 Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME: 96GRF1/515220W	TYPE:	WEIGHT: 1
SPEC.:	DIM.: F 115 x 90	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: 5 Circle	Shielding Angle:

Table--1

UNIT: cd

H(DEC) V(DEC)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-90	0.04	0.03	0.03	0.03	0.03	0.03	0.02	0.03	0.03	0.02	0.02	0.02	0.03	0.02	0.02	0.02	0.03	0.02	0.02
-85	0.04	0.04	0.04	0.05	0.06	0.05	0.04	0.07	0.09	0.09	0.08	0.09	0.11	0.10	0.09	0.10	0.12	0.10	0.09
-80	0.04	0.04	0.04	0.06	0.10	0.10	0.11	0.17	0.23	0.26	0.29	0.33	0.37	0.40	0.42	0.46	0.50	0.50	0.49
-75	0.04	0.04	0.05	0.10	0.14	0.20	0.26	0.39	0.51	0.63	0.74	0.89	1.07	1.18	1.24	1.28	1.29	1.27	1.23
-70	0.04	0.05	0.07	0.13	0.22	0.37	0.54	0.80	1.05	1.35	1.64	1.91	2.11	2.26	2.34	2.38	2.36	2.36	2.33
-65	0.04	0.05	0.09	0.19	0.38	0.67	1.01	1.38	1.84	2.30	2.75	3.15	3.43	3.63	3.79	3.88	3.91	3.94	3.90
-60	0.04	0.05	0.12	0.24	0.63	1.02	1.48	2.04	2.68	3.32	3.92	4.48	4.96	5.36	5.69	6.01	6.17	6.30	6.34
-55	0.04	0.06	0.15	0.43	0.87	1.40	2.02	2.76	3.57	4.42	5.22	6.02	6.77	7.64	8.46	9.47	9.99	10.5	11.0
-50	0.04	0.07	0.19	0.61	1.10	1.78	2.56	3.49	4.56	5.62	6.69	8.09	9.81	11.6	13.5	15.0	16.4	17.1	16.9
-45	0.04	0.08	0.23	0.77	1.37	2.16	3.10	4.29	5.67	6.95	8.70	11.4	14.1	16.5	18.9	21.3	23.8	25.1	25.2
-40	0.04	0.09	0.28	0.89	1.62	2.53	3.64	5.13	6.76	8.74	12.2	15.7	19.0	22.8	26.3	30.3	33.7	35.3	35.8
-35	0.04	0.10	0.37	1.01	1.88	2.87	4.26	6.00	8.12	11.6	16.1	20.4	25.7	31.0	37.7	45.2	53.0	57.0	57.6
-30	0.04	0.10	0.45	1.14	2.11	3.25	4.87	6.92	10.1	15.1	20.2	26.3	33.4	43.2	57.2	70.8	83.0	89.0	89.8
-25	0.04	0.11	0.52	1.27	2.30	3.57	5.47	7.98	12.4	18.2	24.8	32.5	43.7	60.9	80.2	104	126	141	145
-20	0.04	0.12	0.58	1.38	2.48	3.93	6.06	8.93	14.7	21.5	29.2	39.8	57.9	81.1	113	153	189	213	220
-15	0.04	0.12	0.62	1.46	2.62	4.28	6.60	10.0	16.8	24.3	32.8	47.8	71.9	106	153	209	265	318	336
-10	0.04	0.12	0.65	1.52	2.74	4.56	7.01	10.9	18.3	26.3	36.5	56.1	84.8	129	191	269	404	634	732
-5	0.04	0.12	0.67	1.55	2.82	4.77	7.29	11.5	18.7	27.3	38.8	61.8	94.5	147	216	333	685	1288	1581
0	0.04	0.13	0.67	1.57	2.87	4.90	7.41	11.9	18.4	27.5	39.8	63.9	97.9	155	227	366	860	1668	2010
5	0.04	0.13	0.66	1.57	2.90	4.89	7.39	11.8	18.1	26.4	38.6	62.0	94.2	149	222	343	718	1377	1661
10	0.04	0.13	0.64	1.54	2.89	4.78	7.23	11.3	17.4	24.7	36.0	56.6	85.1	132	195	276	434	715	840
15	0.04	0.13	0.60	1.50	2.82	4.60	6.95	10.6	16.1	22.8	32.1	48.5	72.4	107	158	214	276	340	363
20	0.04	0.12	0.56	1.43	2.69	4.36	6.53	9.59	14.6	20.5	28.0	39.7	60.1	83.1	115	155	193	219	225
25	0.04	0.12	0.51	1.33	2.50	4.04	5.98	8.63	12.8	17.7	24.1	32.5	45.6	63.7	83.1	106	128	145	151
30	0.04	0.12	0.46	1.21	2.27	3.72	5.39	7.54	10.9	15.2	20.2	26.4	35.1	45.6	58.7	71.6	82.7	90.5	92.6
35	0.04	0.11	0.39	1.07	2.03	3.33	4.80	6.50	8.97	12.5	16.5	21.4	27.0	33.5	40.3	46.8	53.5	58.0	59.1
40	0.04	0.10	0.33	0.91	1.76	2.90	4.18	5.60	7.24	9.75	12.9	16.6	20.7	25.4	29.1	32.3	35.3	36.8	36.7
45	0.04	0.10	0.29	0.72	1.48	2.44	3.55	4.73	6.02	7.42	9.53	12.2	14.9	18.7	21.8	24.1	24.7	24.8	24.3
50	0.04	0.09	0.25	0.55	1.15	2.02	2.91	3.87	4.90	5.98	7.12	8.59	10.4	12.4	14.3	15.9	16.5	16.8	16.8
55	0.04	0.08	0.20	0.44	0.85	1.52	2.28	3.07	3.83	4.64	5.45	6.29	7.15	8.02	8.84	9.79	10.4	10.7	10.9
60	0.04	0.07	0.16	0.33	0.58	1.01	1.67	2.27	2.84	3.42	3.94	4.50	4.99	5.50	5.95	6.35	6.70	6.89	6.95
65	0.04	0.07	0.14	0.24	0.42	0.66	1.03	1.53	1.94	2.33	2.71	3.02	3.30	3.57	3.89	4.17	4.39	4.57	4.67
70	0.04	0.06	0.11	0.16	0.27	0.43	0.61	0.88	1.20	1.48	1.71	1.92	2.08	2.24	2.38	2.56	2.74	2.88	2.97
75	0.04	0.06	0.09	0.12	0.14	0.25	0.35	0.45	0.55	0.75	0.96	1.09	1.17	1.25	1.32	1.40	1.46	1.52	1.57
80	0.04	0.05	0.07	0.08	0.09	0.13	0.17	0.21	0.24	0.28	0.33	0.39	0.44	0.52	0.58	0.57	0.54	0.55	0.54
85	0.04	0.05	0.06	0.06	0.06	0.07	0.09	0.09	0.09	0.11	0.13	0.12	0.11	0.13	0.14	0.14	0.13	0.14	0.15
90	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.05

C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: MEDIUM
Temperature:25.3°C
Operators:
Test Date:24 January 2023

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.340m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME: 96GRF1/515220W	TYPE:	WEIGHT: 1
SPEC.:	DIM.: F 115 x 90	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: 5 Circle	Shielding Angle:

Table--2

UNIT: cd

H (DEG) V (DEG)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	
-90	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.04	
-85	0.10	0.11	0.10	0.08	0.09	0.10	0.08	0.07	0.07	0.08	0.06	0.04	0.05	0.06	0.04	0.04	0.04	0.04	
-80	0.45	0.41	0.38	0.35	0.33	0.30	0.26	0.20	0.18	0.17	0.13	0.09	0.09	0.09	0.06	0.04	0.04	0.04	
-75	1.21	1.16	1.12	1.05	0.95	0.81	0.71	0.63	0.52	0.41	0.31	0.18	0.15	0.12	0.08	0.05	0.05	0.04	
-70	2.35	2.33	2.28	2.19	2.06	1.86	1.59	1.30	1.07	0.86	0.64	0.46	0.29	0.17	0.11	0.07	0.05	0.04	
-65	3.90	3.86	3.80	3.64	3.38	3.08	2.68	2.25	1.80	1.40	1.06	0.76	0.53	0.29	0.14	0.08	0.06	0.04	
-60	6.34	6.20	5.89	5.47	5.00	4.50	3.96	3.31	2.68	2.07	1.56	1.13	0.78	0.47	0.18	0.10	0.06	0.04	
-55	10.7	10.2	9.46	8.44	7.50	6.36	5.42	4.53	3.63	2.78	2.07	1.56	1.07	0.66	0.29	0.12	0.07	0.04	
-50	16.3	15.5	14.5	13.3	11.7	9.64	7.64	6.12	4.84	3.64	2.65	1.98	1.39	0.86	0.40	0.15	0.08	0.04	
-45	24.1	22.5	20.5	18.1	16.2	14.2	11.2	8.41	6.30	4.72	3.41	2.42	1.71	1.07	0.53	0.17	0.08	0.04	
-40	34.8	32.1	28.3	25.0	21.5	18.3	15.2	11.8	8.42	6.01	4.32	2.89	2.05	1.27	0.66	0.20	0.09	0.04	
-35	54.6	49.4	42.0	34.9	28.7	23.7	19.1	15.5	11.4	7.60	5.30	3.58	2.39	1.50	0.79	0.26	0.10	0.04	
-30	85.4	77.9	66.0	53.3	40.4	31.3	24.3	19.2	14.3	9.59	6.31	4.26	2.79	1.72	0.90	0.31	0.10	0.04	
-25	136	120	98.3	78.4	58.2	40.7	29.6	22.8	17.3	11.7	7.41	4.90	3.17	1.93	1.00	0.35	0.11	0.04	
-20	210	184	146	109	79.4	54.0	36.3	26.2	19.5	13.5	8.39	5.50	3.56	2.14	1.09	0.38	0.11	0.04	
-15	313	258	203	146	102	67.9	42.5	29.3	21.2	14.8	9.58	6.01	3.87	2.31	1.16	0.41	0.12	0.04	
-10	598	384	258	183	121	80.3	49.8	32.9	22.9	15.7	10.4	6.37	4.10	2.45	1.21	0.43	0.12	0.04	
-5	1205	617	318	210	137	87.5	54.8	34.7	23.9	16.3	10.9	6.58	4.26	2.56	1.25	0.44	0.12	0.04	
0	1576	747	342	221	143	93.1	56.8	35.2	24.1	16.5	11.0	6.66	4.34	2.62	1.26	0.44	0.12	0.04	
5	1279	634	319	210	138	89.8	54.7	34.3	23.9	16.2	10.9	6.65	4.32	2.62	1.26	0.44	0.12	0.04	
10	681	401	261	184	123	80.5	50.3	32.4	22.9	15.5	10.4	6.51	4.23	2.58	1.24	0.43	0.12	0.04	
15	332	265	203	146	102	69.0	43.2	29.5	21.2	14.5	9.75	6.22	4.07	2.48	1.18	0.41	0.12	0.04	
20	215	186	146	109	80.3	55.3	36.7	26.8	19.2	13.3	8.82	5.76	3.84	2.33	1.10	0.38	0.12	0.04	
25	144	124	101	80.2	60.0	41.6	30.9	23.5	16.6	11.8	7.86	5.24	3.54	2.13	0.98	0.35	0.11	0.04	
30	90.8	81.8	70.3	56.6	42.2	32.8	26.1	19.6	14.3	10.0	6.76	4.69	3.20	1.90	0.83	0.32	0.11	0.04	
35	57.4	52.7	45.0	37.8	31.4	26.1	21.2	16.0	11.6	8.15	5.75	4.13	2.81	1.65	0.69	0.27	0.10	0.04	
40	35.5	33.4	30.6	27.7	23.9	20.3	16.3	12.4	8.92	6.52	4.82	3.54	2.39	1.37	0.59	0.23	0.10	0.04	
45	23.9	23.0	21.5	19.6	17.2	14.9	12.0	8.86	6.71	5.22	3.92	2.90	1.95	1.07	0.49	0.20	0.09	0.04	
50	16.4	15.8	14.8	13.4	12.0	10.0	7.89	6.40	5.14	4.00	3.11	2.28	1.50	0.77	0.40	0.18	0.09	0.04	
55	10.8	10.4	9.65	8.62	7.69	6.63	5.66	4.69	3.76	3.00	2.33	1.69	1.08	0.59	0.30	0.15	0.08	0.04	
60	6.89	6.66	6.23	5.76	5.23	4.59	3.91	3.22	2.60	2.12	1.64	1.17	0.72	0.41	0.21	0.13	0.07	0.04	
65	4.61	4.48	4.24	3.92	3.49	3.06	2.59	2.17	1.78	1.43	1.10	0.77	0.47	0.27	0.16	0.11	0.07	0.04	
70	2.95	2.87	2.67	2.42	2.13	1.84	1.61	1.36	1.11	0.88	0.66	0.43	0.27	0.17	0.12	0.09	0.06	0.04	
75	1.54	1.48	1.37	1.24	1.11	0.97	0.86	0.75	0.59	0.43	0.31	0.21	0.16	0.10	0.09	0.07	0.06	0.04	
80	0.51	0.48	0.46	0.44	0.40	0.34	0.30	0.25	0.19	0.15	0.14	0.12	0.09	0.07	0.06	0.06	0.05	0.04	
85	0.14	0.12	0.13	0.13	0.11	0.09	0.10	0.10	0.08	0.06	0.07	0.07	0.05	0.04	0.05	0.05	0.04	0.04	
90	0.05	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.03	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	

C Range: 0 - 360DEG

C Interval: 10.0DEG

Test Speed: MEDIUM

Temperature:25.3°C

Operators:

Test Date:24 January 2023

γ Range: 0 - 90DEG

γ Interval: 2.5DEG

Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456

Humidity:65.0%

Test Distance:6.340m [K=1.0000]

Remarks: