


LAMP PHOTOMETRIC REPORT

MODEL: 99POML30/BL		
POWER: 10W	VOLTAGE: 230V	WORKING VOLTAGE: 230V
MANUFACTURER: Elmark Industries JSC		

TOTAL FLUX: 954.39 lm



$\gamma$	C0	C45	C90	C135	C180	C225	C270	C315	$\gamma$	$\Phi$ zone	$\Phi$ total	%
10	369.6	369.6	369.7	369.3	368.8	368.4	368.6	369.1	0- 10	35.67	35.67	3.74
20	343.7	343.7	343.8	343.2	342.4	341.3	341.7	342.7	10- 20	100.9	136.6	14.3
30	303.6	303.5	303.3	302.8	302.0	300.0	300.8	302.1	20- 30	149.2	285.8	29.9
40	253.5	253.1	252.3	252.6	251.5	248.7	249.8	251.3	30- 40	173.8	459.5	48.1
50	197.2	197.2	194.8	196.9	195.1	192.8	192.9	195.7	40- 50	172.8	632.3	66.3
60	138.5	139.0	135.6	138.8	136.7	135.2	134.3	138.3	50- 60	148.8	781.1	81.8
70	80.91	81.39	77.42	80.84	78.60	78.37	77.25	81.45	60- 70	107.0	888.1	93.1
80	27.87	28.87	24.80	28.39	25.63	25.60	24.90	28.46	70- 80	55.50	943.6	98.9
90	0.7146	0.6381	5.019	0.7762	0.8586	0.4422	0.3731	0.4330	80- 90	10.80	954.4	100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG  
C Interval: 10.0DEG  
Test Speed: HIGH  
Temperature:25.3°C  
Operators:  
Test Date:16 November 2022

$\gamma$  Range: 0 - 90DEG  
 $\gamma$  Interval: 5.0DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.00.456  
Humidity:65.0%  
Test Distance:6.265m [K=1.0000]  
Remarks:

```

γ Range: 0 - 90DEG
γ Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

```

```

γ Range: 0 - 90DEG
γ Interval: 5.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

```